



Product Service

# CERTIFICATE

No. B 14 04 87707 001

**Holder of Certificate:** **BREMAS ERSCE S.P.A**  
VIA CASTELLAZZO 9  
20040 CAMBIAGO (MI) MI  
ITALY

**Certification Mark:**



**Product:** **Cutout switches  
(Switch Disconnecter)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** SIC14023.01



**Date,** 2014-04-30  
Page 1 of 2

  
( Fabrizio Gasparella )



Product Service

**CERTIFICATE**  
**No. B 14 04 87707 001**

**Model(s):** **Series CR020V, A1700V**

**Parameters:**

Rated Voltage:	400/690 VAC
Rated Frequency:	50/60 Hz
Rated insulation voltage (Ui):	690 VAC
Rated impulse voltage (Uimp):	6 kV
Conventional free air thermal current (Ith):	25 A
Conventional enclosed thermal current (Ithe):	25 A
Rated short time withstand current (Icw):	0.24 kA
Rated short time making capacity (Icm):	1 kA
Rated conditional short circuit current:	5 kA at 690 VAC
Max. rated operational current:	AC21A: 20 A (690 VAC 3ph) AC3: 14 A (400 VAC 3ph) AC23A: 16 A (400 VAC 3ph)
Poles number:	3P
Degree of protection:	IP20

**Tested according to:** EN 60947-1/A1:2011  
EN 60947-3/A1:2012

**Production Facility(ies):** 87765



Product Service

Page 2 of 2