

Bremas Ersce SpA
Via castellazzo 9 - 20040 Cambiago (MI)

Tel +39 02 95651611 Fax +39 02 95651639 www.bremas.eu info@bremas.it

ISO 9001 Certified Quality System

## Cod. LAA88311




## Standard and Approvals

- Switch according to IEC/EN 60947-3
- Certified UL60947-4-1A and CAN/CSA C22.2 No. 60947-4-1-07
- Suitable as Manual Motor Controller



## Technical characteristics: Body

- 2 pole switch
- Body and button in plastic material
- · IP00 Protection degree
- Command button with lock in ON Ø6mm
- · 4 silver screw terminals
- · Weight: 0,21kg



Rated insulation voltage		Ui	V	250
Rated operating voltage		Ue	V	250
Rated operation frequency			Hz	50/60
Rated Current				
Resistive load		In	Α	8
Inductive load		In	Α	8
Mechanical characteristics				
Mechanical life (120 cycles/hour)				1E5
Electrical life	Sec. EN61058			5E4
Insulation class	Sec. EN61058			II
Connecting capability with flexible wires		Min-Max	mm2	0,75-2,5
Connecting capability with solid wires		Min-Max	mm2	1-2,5
Connecting capability with flexible wires		Min-Max	AWG	19-14
Connecting capability with solid wires		Min-Max	AWG	18-14
Terminal screw				M3,5
Protection degree IEC 529 EN 60529				IP00
Ambient condition				
Operational ambient temperature			°C	T55
Storage ambient temperature			°C	-30 ÷ +70
Withstand to constant humid	·			sec. IEC 60068-2-8
Withstand to cycling humid				sec. IEC 60068-2-30