

Bremas Ersce SpA


Via castellazzo 9 - 20040 Cambiago (MI)

Tel +39 02 95651611 Fax +39 02 95651639

www.bremas.eu info@bremas.it

ISO 9001 Certified Quality System

Cod. LLA438A3



Standard and Approvals


- Switch according to IEC/EN 60947-3
- Certified UL60947-4-1A and CAN/CSA C22.2 No. 60947-4-1-07
 - Suitable as Manual Motor Controller





Technical characteristics: Body


- 3 pole switch with orange unstable lever
- Fixing holes distance 65mm
- · Body and drive in plastic material
- IP00 Protection degree

Dimension Diagram









Ui	V	380
Ue	٧	380
	Hz	50/60
In	Α	15
In	Α	10
		1E5
N61058		5E4
N61058		II
Min-Max	mm2	0,75-2,5
Min-Max	mm2	1-2,5
Min-Max	AWG	19-14
Min-Max	AWG	18-14
		M3,5
		IP00
	°C	T55
	°C	-30 ÷ +70
	•	sec. IEC 60068-2-8
		sec. IEC 60068-2-30
	Ue In In N61058 N61058 Min-Max Min-Max Min-Max	Ue