# DC Disconnect Switch

DX Series

Panel tickness

Net Weight

Shaft protrusion

Switch IP terminal

Pollution degree ins.

Actuator operation forces

Protection degree IEC 529 EN 60529

Switch IP rating mounted on panel Ambient conditions

Operational ambient temperature

Storage ambient temperature

Damp heat test IEC60068-2-30



Bremas Ersce SpA Via castellazzo 9 - 20040 Cambiago (MI) Tel +39 02 95651611 Fax +39 02 95651639 www.bremas.eu info@bremas.it

ISO 9001 Certified Quality System

## DX1503012PATRV4





Max 4 27

1,5

155

IP20

IP66

3 -40°C ÷ +70°C

-40°C ÷ +85°C

90-100% RH at +55 °C

UV resistant

mm

Nm




Technical data according to IEC 60947-3:2015/A2 Ann	exD				
Utilization category			PV1 (DC21B)	PV2	
Rated operational voltage	Ue	V dc	1500	1500	
Rated operational current	le	A dc	30	12	
Rated operational voltage (second rating)	Ue	V dc	-	-	
Rated operational current (second rating)	le	A dc	-	-	
Rated operational voltage (third rating)	Ue	V dc	-	-	
Rated operational current (third rating)	le	A dc	-	-	
Rated operational voltage (fourth rating)	Ue	V dc	1000	1000	
Rated operational current (fourth rating)	le	A dc	60	25	
Rated operational voltage (fifth rating)	Ue	V dc	-	-	
Rated operational current (fifth rating)	le	A dc	-	-	
Rated thermal current	Ith	Α	6	0	
DC Poles		Nr.	:	2	
Rated conditional short-circuit current			51	(A	
Rated insulation voltage	Ui	V dc	1.5	600	
Rated impulse withstand voltage	Uimp	kV	8	3	
Rated short-time withstand current (1s)	lcw	Α	78	30	
Rated short-circuit making capacity	Icm	kA	1	,4	
Power loss per layer at 20A/50A		W	0,2/	1,25	
Max fuse size for short circuit protection	gPV	Α	63		
Mechanical characteristics					
Type of mounting			Panel mounting Head Up Screws w 4x36 fixing tapping screws		
Layers		Nr.	2	2	
Screwdriver orientation for terminals			Hea	d up	
External metal parts (Screws, shaft)			Stainles		
Terminal capacity with flexible/solid wires	Max	mm² AWG		<6 10	
Terminal capacity with fork terminals	Max	mm² AWG		16 (6	
Thread dimensions for terminal screws			N	14	
Terminal screws tightening torque		Nm	1,7 ±	10%	
Tightening torque panel mounting nut		Nm	2+/-	10%	
Tightening torque M3 screw in the actuator		Nm	0,6 ±	10%	



#### Screwdriver orientation for terminals





#### **Positions**



### Electrical Diagram

Layer	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Marking	-1	+1														
	Ϊ́ο	Ϊ́ο														
Marking	١٩	lφ														
Marking 0/OFF	Ϊ́ο	Ιφ														

#### **Dimensions**

